

**INVITATION FOR BID**  
~~August 28, 2024~~ **updated 9/12/24**

|                                |   |
|--------------------------------|---|
| INVITATION FOR BID NUMBER      | IFB 24-026  |
| NAME OF BID                    | Vertical Turbine Pump Repair for CC Williams WWTP   |
| BIDS WILL BE RECEIVED AT       | MAWSS Bid Box<br>Donaghey Business Entrance<br>4725 Moffett Road or PO Box 180249<br>Mobile, AL 36618   |
| BID OPENING DATE               | <del>September 12, 2024</del> <b>September 24, 2024</b>   |
| BID OPENING TIME               | 10:30 am Central Time   |
| AWARD WILL BE MADE BY          | Total Cost and Lead Time  |
| DELIVER MATERIAL TO            | CC Williams WWTP<br>1600 Yeend St.<br>Mobile, AL 36603  |
| ADDITIONAL INFORMATION CONTACT | Barry Smith (251) 378-3503 Email: <a href="mailto:basmith@mawss.com">basmith@mawss.com</a> or<br>Jed Barbour (251) 222-2363 Email: <a href="mailto:jbarbour@mawss.com">jbarbour@mawss.com</a> |
| APPLICABLE SDP POLICY          | 17-01   |


Sealed bids must be in the Purchasing Department no later than the time specified in order to be considered. Submissions received after the deadline will not be considered. Envelopes must bear the name of the supplier, company address and the words “IFB 24-026 Vertical Turbine Pump Repair” or “IFB 24-026 NO QUOTE.” Facsimile or email bids will not be accepted.

All bids must be submitted on the attached forms or your bid will be disqualified. Bidder shall furnish all the information required by the solicitation. The bidder’s name must be typed or printed on the bid sheet, and signed by the bidder or appropriate authorized executive officer of the bidder’s company. Bidders must initial any changes or erasures. Bidders should retain a copy of bids for their records.

Bidders shall acknowledge receipt of all addenda to this solicitation by signing and returning each addendum or by identifying the addendum number and the date on the bid form. Failure to acknowledge receipt of any addendum by a bidder will result in rejection of the bid if MAWSS determines that the addendum contains information that materially changes the requirements.

All bids shall be quoted FOB Destination, freight prepaid with no additional charges. Unless otherwise specified in the bid, all prices will be on a firm-fixed price basis and are not subject to adjustments based on costs incurred. MAWSS reserves the right to reject any or all bids submitted, to waive any informality in any bid or in the bid process, or to terminate the bid process at any time, if deemed by MAWSS to be in MAWSS’s best interest.

**A Purchase Order** and this “Invitation for Bid” with “Specifications,” “Conditions,” “Bid Form,” signed by the successful bidder’s authorized representative, and all attached drawings and other documents furnished by MAWSS to the bidders with the Invitation for Bid in order to illustrate the contract requirements, will constitute a contract for the goods and/or services to be purchased.

  
Joyce Sawyer, Buyer II  
Board of Water and Sewer Commissioners

## IFB 24-026 VERTICAL TURBINE PUMP REPAIR CONDITIONS

The Board of Water and Sewer Commissioners of the City of Mobile will accept bids for the **Vertical Turbine Pump Repair** in our Purchasing Department Bid Box located in the Business Entrance at 4725 Moffett Road, Mobile, AL. 36618 **no later than 10:30 a.m.** local time on ~~September 12, 2024~~ **September 24, 2024**. Bids will be opened immediately after bid closing time in the MAWSS Business Entrance Conference Room. Award will be by **Total Cost and Lead Time**. The bidder offers and agrees, if this bid is accepted, to furnish the items as defined in the specifications for the unit price set opposite each item. Pricing shall be FOB Mobile, Alabama. All items shall be delivered to our **CC Williams WWTP located at 1600 Yeend St., Mobile, AL 36603** or to the job site as needed. The bidder shall state the expected length of delivery/repair time on the Bid Form.

Bidder understands and agrees that manufacturer and part numbers are provided for descriptive purposes only. Items of equal or better quality will be considered but must be approved by MAWSS in writing. Upon delivery, if the quality, durability or performance of any product represented as equal or better is determined by MAWSS to be unsatisfactory, MAWSS will require a suitable substitute or will require that the originally specified item be delivered, at the unit price originally offered by bidder. No substitution for items to be provided pursuant to this contract shall be permitted during the contract period without the express written consent of MAWSS. All items provided shall be for commercial use and for the purposes reflected in the contract documents. No bid on closed out or discontinued item(s) will be accepted. Item(s) that have a determinable shelf life must be disclosed at the time of bid submittal.

Bidder understands that his/her bid shall be good and may not be withdrawn for a period of sixty (60) calendar days after the scheduled closing time for receiving bids. MAWSS shall not be committed to the purchase of a pre-established minimum quantity for any one item.

A bidder may not modify its bid after bid opening. Errors in the extension of unit prices stated in a bid or in multiplication, division, addition or subtraction in a bid may be corrected by the MAWSS Purchasing Buyer prior to award. In such cases, unit prices shall not be changed.

It is the responsibility of the bidder to determine prior to the bid opening whether any amendment, additions, deletions or changes of any type have been made to this Invitation for Bid, Conditions, Specifications, Bid Form or any of the other bid documents. Bid documents and any amendments made to this bid will be posted on our website at [www.mawss.com](http://www.mawss.com).

A copy of the SDP (Supplier Diversity Program) policy that applies to this Invitation For Bid can be furnished upon request. It is the responsibility of the bidder to read and make efforts to meet the goals of this policy. Please contact the Supplier Diversity Department at [supplier.diversity@mawss.com](mailto:supplier.diversity@mawss.com) for any questions regarding this policy. **Bidders MUST acknowledge receipt of this policy by submitting the SDP Policy Acknowledgement and the Subcontracting Plan/Good Faith Effort form with the bid proposal, regardless if using a Diverse Contractor/Supplier or not.**

Contractors are required to use Contractors/Suppliers only in the areas for which the Contractors/Suppliers are certified.

### **Reporting Requirements, if using a diverse contractor/supplier:**

“The Contractor **must file a written report** with MAWSS’s Supplier Diversity Office with a copy delivered to Accounting **once a month** documenting the Contractor’s continuing compliance with the MAWSS Supplier Diversity Program. This report will list all Diverse Contractor/Supplier’s subcontractors and supplier’s currently performing work or providing supplies for the contract.”

A copy of the SDP (Supplier Diversity Program) policy that applies to this Invitation For Bid can be found on our website by clicking on the following link: [https://www.mawss.com/uploads/final--supplier-diversity-17-01--approved-1-7-21-\(updated-changes-2-3-2021\).pdf](https://www.mawss.com/uploads/final--supplier-diversity-17-01--approved-1-7-21-(updated-changes-2-3-2021).pdf).

**Invoicing Requirements:** MAWSS is requiring additional information for all work performed and services provided. On the vendor’s invoice for payment should be a detailed listing of work performed, services provided, dates completed, locations involved and any other pertinent information needed to verify the work and/or services were completed in accordance to the bid specs. This additional information can be supplied in the form of detailed invoices, completed work orders with photos attached, checklists or any other documents used to track the work performed or services provided but details must be included on the actual invoice. A copy of the invoice and these additional details must be sent to the “ADDITIONAL INFORMATION CONTACT” found on Page 1 of the bid documents and a copy emailed to Accounts Payable at [AcctsPayable@mawss.com](mailto:AcctsPayable@mawss.com).

**END OF CONDITIONS**

## IFB 24-026 VERTICAL TURBINE PUMP REPAIR SPECIFICATIONS

The following labor and materials will be supplied for the **repair and installation** of a Sulzer Vertical Turbine Pump (Serial #80281-05).

Bidder should contact manufacturer for detailed information about pump dimensions and other manufacturer specifications for bidding purposes. Successful bidder shall confirm all dimensions and materials when pump is disassembled.

Bidders proposing to use non-OEM parts for the repair of the vertical turbine pump must provide comprehensive documentation from the parts manufacturer that demonstrates the proposed parts meet or exceed the performance, durability, and quality standards of the OEM parts specified in the bid, as well as all applicable engineering standards. Failure to submit this proof of equivalency or superiority will result in the rejection of the bid.

### **Suction Bowl and Impeller**

Supply and install new bowl assembly; machine and bore bowl to nominal size. Complete new bowl assembly must be furnished with bid design flow 17,500 GPM@30ft TDH using 161 brake horse power, and 705 RPM.

The new bowl assembly will include the following new OEM parts:

1. Cast iron tube adapter
2. Iron bowl
3. Bronze tube adapter screw bearing
4. Bronze bowl bearing
5. Bronze impeller
6. Bronze liner
7. Cast iron suction bell
8. Bronze bell bearing
9. Stainless-steel impeller thrust ring, retainer, and stainless-steel bolts
10. Split key

### **New OEM Shaft, Couplings, and Column Tubes**

1. Replace Inner Column Tubes and Inner Column Tube Bushings / Bearings with new.
2. Replace all 416 stainless steel shafts (Motor, Head, Middle Line, Lower Line, and Bowl) with new 416 stainless steel shafts.
3. Replace all Line Shaft Couplings with new **410 stainless-steel couplings**.
4. Replace Head Nut (1) with new.
5. Replace Center Ring (1) with new.
6. Replace flush line with new stainless-steel flush pipe to suction bell bearing. The flush pipe will go through the pump base plate. The pipe will have brackets connected to the column and bowl flange for support.
7. Replace Flush Water Pressure Gauge (1) with new. Pressure gauge should be stainless steel liquid filled gauge containing expected pressure ranges as defined by the pump manufacturer.

## IFB 24-026 VERTICAL TURBINE PUMP REPAIR SPECIFICATIONS (Cont.)

### New OEM Bearings, Seals, and Bushings

1. Replace Mechanical Seal PPC 1200S Mechanical Split Seal 2-3/16" Carbon/Silicon Carbide/AFLAS with new.
2. Replace Throttle Bushing (1) with new.
3. Replace Adapter Bowl to Bowl Bushing (1) with new.

### Equipment Finish

1. Exterior
  - a. Discharge head will be painted using Sherwin Williams' SW7663 Monorail Silver with a two-part epoxy equivalent to manufacturer's original coating.
  - b. Columns below discharge head will be coated with coal tar epoxy in two coats.
  - c. Preparation of substrate and application of coatings shall be in strict accordance with coating manufacturer's requirements.
2. Interior
  - a. Discharge head water passage will be coated with Belzona 5811 immersion grade coating. No exceptions.
  - b. Coat ID of columns below discharge head with Belzona 5811 immersion grade coating. No exceptions.
  - c. Belzona coatings shall be applied only by Belzona trained technician and in strict accordance with Belzona requirements.
  - d. Coating thickness shall be dictated by pump manufacturer's specifications.
  - e. Belzona representative shall be present to inspect substrate and application of Belzona coating. Belzona to provide MAWSS with completed Inspection Report after application of coating.

### Shipping, Delivery, and Start Up

1. Transportation and Installation will be provided by successful bidder.
  - a. Cost of transportation (to and from provided address to successful bidder's workshop) and installation must be included in bid price.
  - b. Pump shall be delivered to 1600 Yeend St., Mobile, AL 36603 upon repair.
  - c. Pump shall be transported from 1600 Yeend St., Mobile, AL 36603 to the successful bidder's repair facility.
2. Successful bidder must provide a qualified technician during installation, adjustments, and start-up.
  - a. Transportation and labor rates of technician(s) must be provided in the cost of the bid.
  - b. Hourly cost and transportation costs must be itemized as required by MAWSS.
3. Successful bidder must supply crane equipment and operator to install pump.
4. Successful bidder shall install motor provided by MAWSS.
  - a. MAWSS to provide electrician to supply power to motor and check for correct rotation of equipment.
5. All fasteners, hardware, and consumables required for proper installation and startup will be provided by successful bidder.
  - a. All fasteners, hardware, and consumables provided must be new. Reuse of fasteners will not be acceptable. All existing fasteners shall be returned to MAWSS.
  - b. Uncoated, weather exposed fasteners must be 316 Stainless Steel.

## **IFB 24-026 VERTICAL TURBINE PUMP REPAIR SPECIFICATIONS (Cont.)**

6. Successful bidder will provide its Representative on site to ensure pump installation is in accordance with pump manufacturer's requirements. Once pump is installed, Representative will prepare pump for startup and observe pump startup, operation through full range of speeds and stop. The Representative shall make any necessary minor adjustments to the pump to provide optimal performance.
7. Successful bidder shall provide to MAWSS an installation report that certifies proper installation of the pump and confirms warranty is valid and in effect.

### **Referenced Specifications and Standards**

Where applicable, the standards and practices identified within the following documents shall be followed unless otherwise specified herein.

- A. UL - UL674 Electric Motors and Generators for use in Hazardous Locations
- B. Electrical Apparatus Service Association's (EASA)-AR100-1998 Recommended Practice for the Repair of Rotating Electrical Apparatus
- C. IEEE- Std. 43, Recommended Practice for Testing Insulation Resistance of Rotating Machinery
- D. IEEE- Std, 112, IEEE Standard Test Procedure for Polyphase Induction Motors and Generators
- E. ISO-Std. 1940-1, Mechanical Vibration- Balance Quality Requirements of Rigid Rotors
- F. NEMA- Std. MG-1-2009, Motors and Generators
- G. ABMA- ANSI/ABMA Std. 7, Shaft and Housing Fits for Metric Radial ball and Roller Bearings.
- H. National Electrical Code (NEC)
- I. National Fire Protection Agency (NFPA)

### **Miscellaneous**

1. All subcontractor use shall be identified in the SDP Subcontracting Plan herein.
  - a. The successful bidder shall perform quality assurance measures to ensure work performed by subcontractor is compliant with this specification.
  - b. Successful bidder acknowledges and agrees that all work performed by subcontractors shall be the responsibility of the successful bidder.
2. MAWSS must be notified when machining begins so visits to location can be made while machining is underway.
  - a. No defective machine work whatsoever shall be installed in the pump.
3. If any additional work is found after inspection that requires more work or materials other than specified in the work scope, a separate quote will be required, along with digital photographs.
  - a. No additional work will be performed without the approval of MAWSS management.
4. All parts of the pump and housing, inside and outside, must be sandblasted according to the manufacturer recommendations.
5. Electrical wiring will be done by MAWSS or a contractor working for MAWSS.

**IFB 24-026 VERTICAL TURBINE PUMP REPAIR  
SPECIFICATIONS (Cont.)**

6. Successful bidder must supply a 2-year warranty covering labor and material costs should the pump fail to work properly during the warranty period as a result of defective parts used by successful bidder and/or subcontractors, and workmanship performed by successful bidder and/or subcontractors.
7. The successful bidder will have 90 days to complete the job.
  - a. Any extensions requested must be requested in writing and approved by CC Williams Plant Manager or Chief Treatment Plant Operator.
8. All original parts removed during rebuild will be returned to Clifton C. Williams WWTP at 1600 Yeend St., Mobile, AL, 36603.
  - a. All parts must be returned before pump will be accepted.
9. Photographs of machining, painting and reassembly of the pump shall be provided.
10. All exceptions must be submitted 5 days prior to bid opening and shown in the bid documents.
11. All replacement parts shall be new and OEM unless specified otherwise herein.
12. A Pump Repair Report must be provided with the repaired pump. The report must contain, at a minimum, the following:
  - a. A narrative that describes the work performed to disassemble and rebuild the pump including descriptions of testing and measurements made during the process.
  - b. All photographs taken throughout the repair should be included.
    - i. Embed labeled photographs in narrative as necessary to show specific defects and rebuild conditions.
  - c. Documentation showing test results and measurements with comparison to manufacturer requirements.
  - d. Receipts from all material and parts-suppliers explicitly identifying make, model number, quantities and prices of parts.
  - e. An itemized invoice of labor, parts, equipment, out-of-house work, etc.

**The pump is located at:**

1600 Yeend St., Mobile, AL 36603

Transportation of the unit from there to the successful bidder's work site shall be included in the bid price. All transportation shall require insurance for the full value of the unit.

MAWSS reserves the right to reject any and all bids.

**Contacts:**

Barry Smith  
Treatment Plant Operator III - CC Williams Plant Manager  
(251) 378-3503 (Office)  
(251) 721-2850 (Cell) [Basmith@mawss.com](mailto:Basmith@mawss.com)

Jed Barbour  
Chief Treatment Plant Operator  
(251) 378-3505 (Office)  
(251) 222-2363 (Cell) [Jbarbour@mawss.com](mailto:Jbarbour@mawss.com)

**END OF SPECIFICATIONS**



**IFB 24-026 VERTICAL TURBINE PUMP REPAIR  
INSURANCE REQUIREMENTS**

- A. **General:** The Supplier shall provide insurance in accordance with the required specifications. A current certificate of insurance must be provided with your bid. MAWSS does not need to be named as an additional insured on this certificate.
- B. **Supplier Coverage:** The Supplier shall not commence work under this Contract until he has obtained all insurance required under the following paragraphs and until such insurance has been approved by the Owner, nor shall the Supplier allow any subcontractor to commence work on his subcontract until all similar insurance required of the subcontractor has been obtained and approved. If the subcontractor does not take out insurance in his own name, the Supplier shall provide such insurance protection for the subcontractor and such subcontractor's employees.
- C. **Casualty Insurance:** The following insurance coverages (with limits not less than specified herein) shall be maintained by the Supplier for the duration of the Contract, affording coverage for any claim arising out of Supplier's operations herein, whether by the Supplier or by any subcontractor or by any Employee or Agent of either:
1. Claims of employees under Worker's Compensation and other similar employee benefit acts, including claims because of bodily injury, occupational sickness or disease, or death.
  2. Claims arising out of bodily injury, sickness, disease, or death of any person other than employee.
  3. Claims for damages arising out of libel, slander, false arrest, detention or imprisonment, malicious prosecution, defamation or violation of right of privacy, wrongful entry or eviction or other right of private occupancy, including claims as a result of an offense related to the employment of a claimant by Contractor (so-called "Personal Injury").
  4. Claims arising out of damage to or destruction of tangible property, including loss of use.
  5. The Supplier shall furnish certification of insurance and policies verifying that the above coverages are in effect before commencing any work, and that each policy is endorsed to give the Owner 30 days notice in writing in the event of cancellation or material change therein.

Policies of Insurance shall state that the Owner and the Owner's employees be named as additional insureds on the Supplier's Automobile Liability and Commercial General Liability policies. In respect to Worker's Compensation, a Waiver of Subrogation shall be issued in favor of the Owner. Where applicable, the U.S. Longshore and Harborworkers Compensation Act Endorsement shall be attached to the policy. Where applicable, the Maritime Coverage Endorsement (to include coverage under Jones Act) shall be attached to the policy. Both the U. S. Longshore and Harborworkers and the Maritime Coverage shall have limits equal to or greater than the employer's liability coverage.

6. Rated by AM Best – A- or better. For non-admitted companies, a rating of A or better by AM Best.
  - a. At the discretion of the Board, worker's compensation insurance may be placed through a qualified worker's compensation self-insurance fund.



b. **Limits of Liability:**

|                                     |  |
|-------------------------------------|--|
| <b>Worker's Compensation</b>        | Statutory  |
| <b>Employers' Liability</b>         | \$500,000 Each Accident<br>\$500,000 by Disease, Policy Limit<br>\$500,000 by Disease, Each Employee   |
| <b>Commercial Automobile</b>        | \$1,000,000 Each Accident<br>Bodily Injury and Property Damage Combined<br>Business Auto Includes All Owned, Leased, Hired and<br>Non-Owned Automobiles  |
| <b>Commercial General Liability</b> | \$1,000,000 per Occurrence<br>\$1,000,000 Personal & Advertising Injury<br>\$2,000,000 General Aggregate per Project<br>\$2,000,000 Products & Completed Operations Aggregate<br>\$100,000 Fire Damage Liability |

**Umbrella Liability:** In addition to the basic limits previously set out for Commercial General Liability, Products and Completed Operations, Automobile Liability and Worker's Compensation, coverage shall be issued with a "pay on behalf of" wording, including Personal Injury and other extensions, and provide coverage at least as broad as that afforded by the primary insurance policies.

**Extensions (only if applicable):**

|                                |  |
|--------------------------------|--|
| Blanket Contractual Liability  | Blanket Collapse and Underground Coverage            |
| Personal Injury                | Broad Form Property (including Completed Operations) |
| Host Liquor Liability          | Employees as Additional Insureds                     |
| Non-owned Watercraft Liability | Incidental Medical Malpractice                       |
| Worldwide Products             | Extended Bodily Injury (Assault and Battery)         |
| Fire Legal Liability           |  |
| Newly Acquired Organizations   |  |

When and if the use of explosives for blasting purposes appears necessary or desirable, such methods shall not be undertaken without written authorization of the Owner, and then only provided that acceptable extensions of liability coverage have been obtained specifically to include the explosion ("X") hazard and the collapse ("C") hazard. The policy of general liability shall include the special underground property damage coverage (providing the so-called "U" hazard) on a blanket basis.

- D. **Owner's Protective Liability:** The Supplier shall furnish from a carrier acceptable to the Owner, a policy of liability insurance, commonly called "Owner's Protective Liability" in the name of the Board of Water and Sewer Commissioners of the City of Mobile, d/b/a MAWSS, providing "Independent Contractor's Coverage" for the operations embraced by this Contract with limits of \$1,000,000 bodily injury and \$1,000,000 property damage. Policy shall be endorsed that the premium is to be paid by the named Supplier.

**END OF INSURANCE**

**IFB 24-026 VERTICAL TURBINE PUMP REPAIR  
SDP POLICY ACKNOWLEDGEMENT\***

A copy of the SDP (Supplier Diversity Program) policy that applies to this Invitation For Bid has been included in this package. It is the responsibility of the bidder to read and make efforts to meet the goals of this policy. Please contact the Supplier Diversity Department at [supplier.diversity@mawss.com](mailto:supplier.diversity@mawss.com) for any questions regarding this policy.

**Bidders MUST acknowledge receipt of this policy and submit the documentation with the bid proposal.**

Bidders shall take all necessary and reasonable steps in accordance with this Policy to ensure that Diverse Contractors/Suppliers have the maximum allowable opportunity to compete for subcontracts and contracts for services, supplies, or other goods. Bidders shall not discriminate in awarding subcontracts and supplier contracts on the basis of race, color, national origin, ethnicity, or sex, during the bid process as well as during performance of a MAWSS contract.

**The following documentation must be included in the bid proposal.**

- SDP Policy Acknowledgement **and**
- Subcontracting Plan

Please refer to the attached policy for more information regarding these requirements as well as all other requirements, if participating in the SDP Program.

The signer declares under penalty of perjury that she/he is authorized to sign this document and bind the company or organization to the all of the requirements of this policy.

Company Name \_\_\_\_\_

Submitted By \_\_\_\_\_ Title \_\_\_\_\_  
Please Print

Signature \_\_\_\_\_ Date \_\_\_\_\_

**\*Required to sign and return with bid**

**IFB 24-026 VERTICAL TURBINE PUMP REPAIR  
SUBCONTRACTING PLAN/GOOD FAITH EFFORT\***

In order for your proposal to be considered, must complete all blanks in this Subcontracting Plan and sign with a handwritten signature where indicated below and include this form in your proposal.

**Failure to fill in the blanks on this Subcontracting Plan and/or to include a handwritten signature may cause for rejection of your bid.**

It is MAWSS's goal that in all contracts, contractors shall make a demonstrated good faith effort to award 15% of the contract amount to certified Diverse Contractors/Suppliers as subcontractors and/or suppliers performing commercially useful functions which are consistent with contract requirements.

Copies of MAWSS SDP Policy 16-01 (for public works projects), SDP/Supplier Diversity Policy 17-01 (for contracts for other goods and services), MAWSS's list of certified Disadvantaged Business Enterprises (SDPs) / Diverse Suppliers, and lists of organizations that have information on SDPs/Diverse Suppliers are available from MAWSS's Supplier Diversity Office by emailing [supplier.diversity@mawss.com](mailto:supplier.diversity@mawss.com).

|   |          |
|---|----------|
| STATE WHAT PERCENTAGE OF THE WORK FOR THIS CONTRACT YOU PLAN TO AWARD TO SDP/DIVERSE SUPPLIER SUBCONTRACTORS AND/OR VENDORS | TOTAL %  |
| ESTIMATED TOTAL DOLLAR AMOUNT TO BE AWARDED TO SDP/DIVERSE SUPPLIER   | TOTAL \$ |
| AMOUNT BID FOR THIS CONTRACT  | TOTAL \$ |

Please list below all subcontractors and suppliers which you plan to use for this contract. Also indicate which of these are SDPs / Diverse Suppliers by writing "Yes" or "No" where indicated. Also list for each the percentage of the total contract amount to be performed by each and the certification group the SDP / Diverse Supplier is certified with. Attach additional sheets if needed.

| SUBCONTRACTOR/VENDOR NAME | SDP/DIVERSE SUPPLIER<br>(Yes or No) | % OF CONTRACT | CERTIFICATION GROUP<br>(MAWSS, ALDOT, ADECA, SRMSDC, BCIA) |
|---------------------------|-------------------------------------|---------------|--|
| _____                     | _____                               | _____         | _____  |
| _____                     | _____                               | _____         | _____  |
| _____                     | _____                               | _____         | _____  |
| _____                     | _____                               | _____         | _____  |
| _____                     | _____                               | _____         | _____  |
| _____                     | _____                               | _____         | _____  |

**CAUTION: ACCURATELY COMPLETE ALL PARTS OF THIS FORM AND SIGN BELOW.**

**GOOD FAITH EFFORT ACKNOWLEDGEMENT/AFFIDAVIT**

**I/WE EXERCISED GOOD FAITH TO COMPLY WITH THIS PLAN AND MAWSS' SDP REQUIREMENTS.**

\_\_\_\_\_  
BIDDER/COMPANY

\_\_\_\_\_  
BY (Signature)

**\*Required to sign and return with bid**

**IFB 24-026 VERTICAL TURBINE PUMP REPAIR  
BID SHEET**

**Total Cost\***                      \$ \_\_\_\_\_

**\*Must include all costs such as transportation, installation, labor rates, & 2-year warranty.**

**Estimated time of completion:** \_\_\_\_\_

**Company Name** \_\_\_\_\_ **Payment Terms** \_\_\_\_\_

**Address** \_\_\_\_\_

**City, State, Zip** \_\_\_\_\_

**Submitted By** \_\_\_\_\_ **Title** \_\_\_\_\_  
Please Print

**Phone** \_\_\_\_\_ **Email Address** \_\_\_\_\_  
Please Print

The signer declares under penalty of perjury that she/he is authorized to sign this document and bind the company or organization to the all of the terms and conditions of this agreement.

**Signature** \_\_\_\_\_ **Date** \_\_\_\_\_